Date: _____

BUILDING INSPECTOR'S OFFICE S 4295 South Buffalo Street Orchard Park, New York 14127-2609



Phone: 716-662-6430 Fax: 716-662-6419 www.orchardparkny.org

Fire Protection Additional Information

Fire Code of New York State Chapter 9 Fire Protection Systems

Section 901.2 states Construction Documents are required for installation, rehabilitation or modification of any Fire Protection System. Construction Documents must be summited for review and approval prior to the fire system installation.

Permit Requirements

- Orchard Park Permit Application
- O Documentation, where applicable.
- Manufactures specs, where applicable. PDF is acceptable
 - 1. **Alarm Specs**: panels, annunciators, horn strobes, detectors and alarms.
 - 2. Sprinkler Systems specs: sprinkler heads, flow alarms, tamper switches, back flow devices.
 - 3. **Suppression Systems**: hoods, fans, sprinkler heads, extinguisher, fusible links.
- Calculations, where applicable, PDF acceptable.
- 1. Sprinkler and Fire Department Connection: hydraulic calculations are required.
- Plans 2 sets of fire Protection Equipment drawings are required.
- Section 901.2.1 states that the Statement of Compliance is a requirement of the contractor, in which to furnish a written statement confirming that the system has been installed in accordance with the approved plans and manufactures specifications.

Final Approval Requirements

- O **Issued Permit,** the permit is required prior to installation of Fire Protection Equipment.
- Written Statement of Design Deviation, where applicable changes have been made after the permit application has been submitted.
- Acceptance Test, The Fire Protection Equipment is required to be tested, certified and submitted.
- Statement of Compliance this certificate of compliance is issued to complete the process.

Important Information

- Section **901.5.1** states that it is unlawful to occupy any portion of a building or structure until fire detection, alarm and suppression systems have been approved.
- Section 901.6 states that the Fire Protection Systems are required to be maintained and tested.
- Section 901.6.1 states and describes the referenced Standards used for maintenance and the testing requirements for each type of protection system.

Fire Protection